

Fluoride Concentrations Auckland Wide		2013				2014						
Treatment Plant	Component Units	No. of Samples	Maximum	Minimum	Average	No. of Samples	Maximum	Minimum	Average	MAV DWSNZ	MOH	US DHHS
Helensville WTP Treated	mg/L	1	0.03	0.03	0.03	12	0.06	0.02	0.04	1.5	0.7 - 1.0	0.7
Huia Village WTP Treated	mg/L	1	0.00	0.00	0.00	1.00	0.00	0.00	0.00	1.5	0.7 - 1.0	0.7
Waiuku WTP Treated	mg/L	1	0.06	0.06	0.06					1.5	0.7 - 1.0	0.7
Huia WTP Treated	mg/L	52	1.10	0.00	0.79	53	1.10	0.16	0.90	1.5	0.7 - 1.0	0.7
Waiuku Rd WTP Treated	mg/L	1	0.06	0.06	0.06	1	0.05	0.05	0.05	1.5	0.7 - 1.0	0.7
Muriwai WTP Treated	mg/L	1	0.05	0.05	0.05	1	0.06	0.06	0.06	1.5	0.7 - 1.0	0.7
Waikato WTP Treated	mg/L	65	0.96	0.00	0.73	52	1.10	0.78	0.91	1.5	0.7 - 1.0	0.7
Onehunga WTP Treated	mg/L	53	0.18	0.04	0.10	53	0.90	0.11	0.17	1.5	0.7 - 1.0	0.7
Snells/Algies WTP Treated	mg/L	1	0.13	0.13	0.13	1	0.13	0.13	0.13	1.5	0.7 - 1.0	0.7
Waiau Beach WTP	mg/L	1	0.25	0.25	0.25	12	0.28	0.16	0.24	1.5	0.7 - 1.0	0.7
Patumahoe WTP Treated	mg/L	1	0.07	0.07	0.07	1	0.07	0.07	0.07	1.5	0.7 - 1.0	0.7
Waitakere WTP Treated	mg/L	52	1.10	0.03	0.80	51	1.10	0.80	0.94	1.5	0.7 - 1.0	0.7
Warkworth WTP Treated	mg/L	1	0.02	0.02	0.02	1	0.00	0.00	0.00	1.5	0.7 - 1.0	0.7
Hickeys WTP Treated	mg/L	86	0.99	0.03	0.71					1.5	0.7 - 1.0	0.7
Glenbrook Beach WTP Treated	mg/L	1	0.06	0.06	0.06	1	0.06	0.06	0.06	1.5	0.7 - 1.0	0.7
Wellsford WTP Treated	mg/L	1	0.03	0.03	0.03	1	0.03	0.03	0.03	1.5	0.7 - 1.0	0.7
Ardmore WTP Treated A	mg/L	47	1.00	0.00	0.75	53	1.10	0.74	0.91	1.5	0.7 - 1.0	0.7
Cornwall Road WTP Treated	mg/L	1	0.05	0.05	0.05	1	0.05	0.05	0.05	1.5	0.7 - 1.0	0.7
Clarks Beach WTP Treated	mg/L	14	0.79	0.06	0.42	24	0.77	0.42	0.53	1.5	0.7 - 1.0	0.7
Ardmore WTP Treated B	mg/L	35	1.00	0.64	0.85					1.5	0.7 - 1.0	0.7
Ardmore WTP Treated B1	mg/L	17	0.96	0.64	0.83	53	1.20	0.73	0.89	1.5	0.7 - 1.0	0.7
Buckland WTP Treated	mg/L	1	0.06	0.06	0.06					1.5	0.7 - 1.0	0.7
Bombay WTP Treated	mg/L	1	0.04	0.04	0.04	1	0.05	0.05	0.05	1.5	0.7 - 1.0	0.7
Ardmore WTP Treated B2	mg/L	17	0.96	0.64	0.82	53	1.20	0.74	0.90	1.5	0.7 - 1.0	0.7
Victoria Avenue WTP Treated Water	mg/L					1	0.06	0.06	0.06	1.5	0.7 - 1.0	0.7