

Auckland Fluoride Readings

Fluoride target reduced from 26 January

Sample Date	Component Units	Waikato WTP	Ardmore WTP - Treated A	Ardmore WTP - Treated B1	Ardmore WTP - Treated B2	Huia WTP	Waitakere WTP	MAV DWSNZ	MOH	Watercare/ Auckland Council Target	US DHHS
2/11/2015	mg/L	0.77	0.89	0.85	0.85	1.10	1.20	1.5	0.7 - 1.0	0.7	0.7
9/11/2015	mg/L	0.90	0.82	0.76	0.76	1.10	1.10	1.5	0.7 - 1.0	0.7	0.7
16/11/2015	mg/L	0.76	0.83	0.80	0.81	1.10	1.00	1.5	0.7 - 1.0	0.7	0.7
23/11/2015	mg/L	0.82	0.84	0.84	0.83	0.94	1.10	1.5	0.7 - 1.0	0.7	0.7
30/11/2015	mg/L	0.89	0.79	0.77	0.79	0.87	0.93	1.5	0.7 - 1.0	0.7	0.7
7/12/2015	mg/L	0.82	0.78	0.78	0.78	0.86	0.84	1.5	0.7 - 1.0	0.7	0.7
14/12/2015	mg/L	0.80	0.74	0.79	0.79	0.89	0.90	1.5	0.7 - 1.0	0.7	0.7
21/12/2015	mg/L	0.92	0.77	0.73	0.71	0.90	0.95	1.5	0.7 - 1.0	0.7	0.7
29/12/2015	mg/L	0.76	0.71	0.78	0.78	0.82	1.00	1.5	0.7 - 1.0	0.7	0.7
5/01/2016	mg/L	0.84	0.73	0.75	0.75	0.87	1.10	1.5	0.7 - 1.0	0.7	0.7
11/01/2016	mg/L	0.84	0.72	0.67	0.68	0.87	0.90	1.5	0.7 - 1.0	0.7	0.7
18/01/2016	mg/L	0.82	0.72	0.73	0.73	0.86	0.91	1.5	0.7 - 1.0	0.7	0.7
25/01/2016	mg/L	0.81	0.81	0.84	0.84	0.85	0.85	1.5	0.7 - 1.0	0.7	0.7
2/02/2016	mg/L	0.86	0.78	0.74	0.75	0.80	0.84	1.5	0.7 - 1.0	0.7	0.7
9/02/2016	mg/L	0.84	0.82	0.80	0.79	0.87	0.86	1.5	0.7 - 1.0	0.7	0.7
15/02/2016	mg/L	0.78	0.81	0.74	0.73	0.85	0.87	1.5	0.7 - 1.0	0.7	0.7
22/02/2016	mg/L	0.81	0.79	0.72	0.72	0.85	0.75	1.5	0.7 - 1.0	0.7	0.7
29/02/2016	mg/L	0.75	0.78	0.71	0.71	0.82	0.71	1.5	0.7 - 1.0	0.7	0.7
7/03/2016	mg/L	0.79	0.82	0.67	0.68	0.85	0.87	1.5	0.7 - 1.0	0.7	0.7
14/03/2016	mg/L	0.75	0.76	0.73	0.73	0.86	0.86	1.5	0.7 - 1.0	0.7	0.7
21/03/2016	mg/L	0.81	0.81	0.74	0.74	0.86	0.84	1.5	0.7 - 1.0	0.7	0.7
28/03/2016	mg/L	0.83	0.89	0.80	0.80	0.81	0.75	1.5	0.7 - 1.0	0.7	0.7
4/04/2016	mg/L	0.76	0.86	0.73	0.73	0.80	0.74	1.5	0.7 - 1.0	0.7	0.7
11/04/2016	mg/L	0.64	0.78	0.71	0.71	0.84	0.84	1.5	0.7 - 1.0	0.7	0.7
18/04/2016	mg/L	0.80	0.77	0.75	0.76	0.79	0.73	1.5	0.7 - 1.0	0.7	0.7
26/04/2016	mg/L	0.77	0.76	0.71	0.71	0.72	0.77	1.5	0.7 - 1.0	0.7	0.7
2/05/2016	mg/L	0.80	0.75	0.71	0.72	0.74	0.80	1.5	0.7 - 1.0	0.7	0.7
9/05/2016	mg/L	0.78	0.73	0.71	0.71	0.74	0.77	1.5	0.7 - 1.0	0.7	0.7
16/05/2016	mg/L	0.80	0.75	0.75	0.74	0.73	0.77	1.5	0.7 - 1.0	0.7	0.7
23/05/2016	mg/L	0.71	0.72	0.72	0.71	0.74	0.74	1.5	0.7 - 1.0	0.7	0.7

Note: Waikato WTP readings are taken a day later than the remainder of the Network.